

## Test Report PPR-3205

**Test object:** Cold Shrink Indoor Termination type CSTI and Cold Shrink Outdoor Termination Type CSTO for screened single core polymeric cables without armour  
TE Connectivity reference: CSTI-6122-ML-2-13, CSTO-6122-ML-2-13

**Test performed:** Requirements according to CENELEC HD 629.1 S3 from 2015-09 (Draft) Table 6 Sequences A1 and A3 and Table 7 for rated voltage  $U_0/U (U_m)$  20,8/36(42) kV

**Test result:** All samples passed the test requirements in accordance with the CENELEC HD 629.1 S3:2015 (Draft) table 6 Sequences A1 and A3 and 7 for rated voltage  $U_0/U (U_m)$  20,8/36(42) kV

**Pages:** 45

Tested by:	<b>Bayram Cataltepe</b> (Laboratory Technician)	Signature: 	Date: 27.01.17
Prepared by:	<b>Christoph Baier</b> (Laboratory Manager)	Signature: 	Date: 27.01.17
Released by:	<b>Per Christian Olving</b> (Product Manager)	Signature: 	Date: 27/1-17

**Tyco Electronics Raychem GmbH**  
a TE Connectivity LTD. Company  
Finsinger Feld 1  
D-85521 Ottobrunn  
Munich, Germany  
Tel.: +49-89-6089-0  
Fax: +49-89-6096-345

© Raychem reports may only be used in their original form



# Content

<b>1</b>	<b>General information.....</b>	<b>3</b>
1.1	Description of the test objects.....	3
1.2	Description of the test cables.....	3
1.3	Test standards.....	4
1.4	Test facilities.....	4
<b>2</b>	<b>Test sequence and requirements.....</b>	<b>5</b>
<b>3</b>	<b>Test setups.....</b>	<b>6</b>
3.1	AC voltage dry withstand.....	6
3.2	Partial discharge at ambient temperature.....	7
3.3	Partial discharge at elevated temperature.....	8
3.4	Impulse voltage.....	9
3.5	Heating cycle voltage in air.....	10
3.6	Immersion test for outdoor terminations.....	11
3.7	Humidity test for indoor terminations.....	11
<b>4</b>	<b>Results.....</b>	<b>12</b>
4.1	AC voltage dry withstand.....	12
4.2	Partial discharge at ambient temperature.....	12
4.3	Impulse voltage at elevated temperature.....	13
4.4	Heating cycle voltage in air.....	18
4.5	Immersion test for outdoor terminations.....	19
4.6	Partial discharge at elevated and ambient temperature.....	21
4.7	Impulse voltage at ambient temperature.....	23
4.8	AC voltage dry withstand.....	32
4.9	Partial discharge at ambient temperature.....	33
4.10	Examination.....	33
4.11	Humidity test.....	34
4.12	Examination.....	36
<b>A.</b>	<b>Appendices.....</b>	<b>37</b>
A.1	Identification of test cable 50mm <sup>2</sup> .....	37
A.2	Identification of test cable 150mm <sup>2</sup> .....	38
A.3	Identification of test cable 95mm <sup>2</sup> .....	39
A.4	Installation instructions.....	40
A.5	Kit content lists.....	45

## 1 General information

### 1.1 Description of the test objects

Test objects:	4 indoor terminations type CSTI-6122-ML-2-13 installed on 50mm <sup>2</sup> (test objects A), 4 outdoor terminations type CSTO-6122-ML-2-13 installed on 50mm <sup>2</sup> (test objects B), 4 indoor terminations type CSTI-6122-ML-2-13 installed on 150mm <sup>2</sup> (test objects C), 4 outdoor terminations type CSTO-6122-ML-2-13 installed on 150mm <sup>2</sup> (test objects D) 4 indoor terminations type CSTI-6122-ML-2-13 installed on 95mm <sup>2</sup> (test objects E)
Manufacturer:	TE Connectivity Kunshan PRC
TE kit reference:	CSTI-6122-ML-2-13, CSTO-6122-ML-2-13
Part description:	CSTI-35-BD-18-533-FS, CSTO-35-BD-18-533-FS
Rated voltage $U_0/U (U_m)$ :	20,8/36 (42) kV
Application range:	screened single core polymeric cables without armour with diameter over insulation from 24,5 mm up to 33,5 mm
Connector type:	Mechanical cable lug BLMT-35/150-13
Installation instructions:	See <b>Appendix A.4</b>
List of kit content:	See <b>Appendix A.5</b>

### 1.2 Description of the test cables

Length of each test loop:	4.2 m (without test object)
Cable type:	Single core cable with XLPE insulation, type VDE 0276 N2XS <sub>Y</sub> (see <b>Appendix A.1</b> )
Cable conductor material:	Copper
Cable conductor cross-section:	50 mm <sup>2</sup>
Rated voltage of cable $U_0/U (U_m)$ :	18/30 (36) kV
Length of each test loop:	4.2 m (without test object)
Cable type:	Single core cable with XLPE insulation, type VDE 0276 NA2XS <sub>2Y</sub> (see <b>Appendix A.2</b> )
Cable conductor material:	Aluminium
Cable conductor cross-section:	150 mm <sup>2</sup>
Rated voltage of cable $U_0/U (U_m)$ :	18/30 (36) kV

Length of each test loop: 3.0 m (without test object)  
Cable type: Single core cable with XLPE insulation, type VDE 0276  
NA2XS(F)2Y (see **Appendix A.3**)  
Cable conductor material: Aluminium  
Cable conductor cross-section: 95 mm<sup>2</sup>  
Rated voltage of cable  $U_0/U (U_m)$ : 18/30 (36) kV

### 1.3 Test standards

Requirements according to CENELEC HD 629.1 S3 from 2015-09 (Draft): *Test requirements on accessories for use on power cables of rated voltage from 3,6/6 (7,2) kV up to 20,8/36 (42) kV, Part 1: Cables with extruded insulation*; Table 6 Sequences A1 and A3 and Table 7 for rated voltages  $U_0/U (U_m)$  20,8/36(42) kV

### 1.4 Test facilities

The installation of the test objects as well as the electrical tests were carried out by technicians of Tyco Electronics Raychem GmbH in the High Voltage Laboratory in Ottonbrunn/Germany.

## 2 Test sequence and requirements

The test requirements are according to CENELEC HD 629.1 S3 from 2015-09 (Draft), Table 6 Sequences A1 and A3 and Table 7 for rated voltage  $U_0/U (U_m)$  20,8/36 (42) kV.

	Test	Test clause of EN 61442	Test requirements	Notes
1	AC voltage dry withstand	4	5 min at 93,5 kV, no breakdown	-
2	Partial discharge at ambient temperature	7	Max. 10 pC at 42 kV	-
3	Impulse voltage at elevated temperature	6	10 impulses of each polarity at $\pm 200$ kV, target temperature 95 - 100°C, no breakdown	-
4	Heating cycle voltage in air	9	126 heat cycles, target temperature 95 - 100°C, 52 kV, no breakdown	-
5	Immersion	9.4	10 heat cycles, target temperature 95 - 100°C	Only required for outdoor terminations;
6	Partial discharge at elevated temperature	7	Heating up, target temperature 95 - 100°C, max. 10 pC at 42 kV	-
7	Partial discharge at ambient temperature	7	Max. 10 pC at 42 kV	-
8	Impulse voltage at ambient temperature	6	10 impulses of each polarity at $\pm 200$ kV, no breakdown	-
9	AC voltage dry withstand	4	5 min at 93,5 kV, no breakdown	-
10	Partial discharge at ambient temperature	7	Max. 10 pC at 42 kV	-
11	Examination	-	-	-

The test requirements are according to CENELEC HD 629.1 S3 from 2015-09 (Draft), Table 6 Sequences A3 for rated voltage  $U_0/U (U_m)$  20,8/36 (42) kV.

	Test	Test clause of EN 61442	Test requirements	Notes
1	Humidity test	13	300 h at 26 kV	Only required for indoor terminations
2	Examination	-	-	-


### 3 Test setups

#### 3.1 AC voltage dry withstand

The cable conductors of the test objects were connected to an AC voltage provided by a test transformer, the screens were put on ground potential (**Figure 1**). The voltage measurement was carried out with a capacitive divider. The measuring uncertainty within a range of 10 kV to 300 kV was 0.91%.

Technical data:

TT	Test transformer:	350 kV, 175 kVA, 50 Hz
C-Div	Capacitive divider:	75 pF (high voltage side)
TO	Test object	



**Figure 1:** AC voltage dry withstand test setup

Measurement equipment:


Object	Type	Calibration number	Calibration date
Capacitive divider	TUR MCF 75/350 P	000132 D-K-17601-01-00	2015-03
Coaxial cable	-	000132 D-K-17601-01-00	2015-03
AC peak voltmeter	LDIC voltage unit	000132 D-K-17601-01-00	2015-03

### 3.2 Partial discharge at ambient temperature

The cable conductors of the test objects were connected to an AC voltage provided by a test transformer, the screens were put on ground potential (**Figure 2**). The voltage measurement was carried out with a capacitive divider. The measuring uncertainty within a range of 10 kV to 300 kV was 0.91%. For the extraction of the partial discharge (PD) signals, a coupling capacitor and a quadrupole (i.e. measuring impedance) were used. A coil was installed to block interferences coming from the transformer side of the test setup. Prior to the test, the complete test arrangement including the test object was calibrated using a PD-calibrator.

Technical data:

TT	Test transformer:	350 kV, 175 kVA, 50 Hz
C-Div	Capacitive divider:	75 pF (high voltage side)
C-C	Coupling capacitor:	1000 pF
Q	Quadrupole	
L	Coil	
TO	Test object	



**Figure 2:** Partial discharge test setup

Measurement equipment:

Object	Type	Calibration number	Calibration date
Capacitive divider	TUR MCF 75/350 P	000132 D-K-17601-01-00	2015-03
Coaxial cable	-	000132 D-K-17601-01-00	2015-03
AC peak voltmeter	LDIC voltage unit	000132 D-K-17601-01-00	2015-03
PD-measurement system	LDIC LDD-5	calibrated with PD-calibrator	n/a
PD-calibrator	LDIC LDC-5	RY-1341 & verified with PD-calibrator tester	2016-06-01
PD-calibrator tester	LDIC LDT-5	RY-1222	2016-07-15

### 3.3 Partial discharge at elevated temperature

The cable conductors of the test objects were connected to an AC voltage provided by a test transformer, the screens were put on ground potential (**Figure 2**). The voltage measurement was carried out with a capacitive divider. The measuring uncertainty within a range of 10 kV to 300 kV was 0.92%. For the extraction of the partial discharge (PD) signals, a coupling capacitor and a quadrupole (i.e. measuring impedance) were used. A coil was installed to block interferences coming from the transformer side of the test setup. Prior to the test, the complete test arrangement including the test object was calibrated using a PD-calibrator. The test objects were installed in a way that a closed loop was formed, which could be heated using an induced AC current provided by a heating transformer supplied by a variable transformer. The cable should be heated to a conductor temperature 5 - 10 K above the maximum cable conductor temperature in operation, i.e. 95 - 100°C for XLPE-cables. The temperature of the cable conductor was measured in-line using a reference cable of the same type as the test loops with a length of 3 m, a type K thermocouple and fibre optical temperature measurement transmission systems. The current was measured by a clamp meter.




### 3.4 Impulse voltage

The cable conductors of the test objects were connected to a Marx-generator with 8 stages, a maximum cumulative charging voltage of 800 kV and a maximum impulse energy of 24 kJ, the screens were put on ground potential (**Figure 3**). The voltage measurement was carried out with a resistive-capacitive divider and an impulse measurement system. The measuring uncertainty for the voltage amplitude within a range of 50 kV to 450 kV was 0.88% and for the time max. 4.76%.

Technical data:

Configuration	4 times 2 parallel stages in series:	400 kV max. charging voltage
RC-Div	Damped capacitive divider:	670 pF, 100 $\Omega$ (high voltage side)
TO	Test object	



**Figure 3:** Impulse voltage test setup

Measurement equipment:


Object	Type	Calibration number	Calibration date
Damped capacitive divider	Haefely CS1000	000177 D-K-17601-01-00	2015-03
Coaxial cable	-	000177 D-K-17601-01-00	2015-03
Digital transient recorder	Haefely DiAS 733	000177 D-K-17601-01-00	2015-03

### 3.5 Heating cycle voltage in air

The cable conductors of the test objects were connected to an AC voltage provided by a test transformer, the screens were put on ground potential (**Figure 4**). The voltage measurement was carried out with a capacitive divider. The measuring uncertainty within a range of 10 kV to 100 kV was 0.59%. The test objects were installed in a way that a closed loop was formed, which could be heated using an induced AC current provided by a heating transformer supplied by a variable transformer. The cable should be heated to a conductor temperature 5 - 10 K above the maximum cable conductor temperature in operation, i.e. 95 - 100°C for XLPE-cables. The temperature of the cable conductor was measured in-line using a reference cable of the same type as the test loops with a length of 3 m, a type K thermocouple and fibre optical temperature measurement transmission systems. The heating cycles were controlled by an automated regulation system.

Technical data:

TT	Test transformer:	100 kV, 100 kVA, 50 Hz
C-Div	Capacitive divider:	100 pF (high voltage side)
VT	Variable transformer:	230 V, 6.9 kVA, 50 Hz
HT	Heating transformer:	9.2 kVA
TC	Thermocouple:	Type K
TO	Test object	



**Figure 4:** Heating cycle voltage test setup (exemplary for one cable cross section and one type of termination)

### 3.6 Immersion test for outdoor terminations

The test objects were installed in a way that a closed loop was formed, which could be heated using an induced AC current provided by a heating transformer supplied by a variable transformer. The cable should be heated to a conductor temperature 5 - 10 K above the maximum cable conductor temperature in operation, i.e. 95 - 100°C for XLPE-cables. The temperature of the cable conductor was measured in-line using a reference cable of the same type as the test loops with a length of 3 m, a type K thermocouple and fibre optical temperature measurement transmission systems. The heating cycles were controlled by an automated regulation system. The test objects were mounted upside down in a water tank with a water height of min. 0.3 m above every part of the termination.

### 3.7 Humidity test for indoor terminations

The test objects were placed in a special chamber with a volume of about 10 m<sup>3</sup>. The humidity was produced by means of special nozzles able to spray water into the chamber and adjusted to a flow of (0.4 ± 0.1) l/h/m<sup>3</sup>. Prior to the test the conductivity of the water has been adjusted by adding salt resulting in a conductivity of (70 ± 10) mS/m.

## 4 Results

### 4.1 AC voltage dry withstand

Date: 2016-10-11  
 Ambient temperature: 25°C  
 Ambient relative humidity: 38%  
 Ambient pressure: 953 hPa

Test objects	Test voltage $\hat{u}/\sqrt{2}$	Duration	Result
A	93,3 kV	5 min	No breakdown
B			No breakdown
C	93,5 kV	5 min	No breakdown
D			No breakdown

Note: All test objects installed on the same cable cross section were tested simultaneously.

Requirement: No breakdown shall occur.

Result: All test objects passed the test.

### 4.2 Partial discharge at ambient temperature

Date: 2016-10-11  
 Ambient temperature: 25°C  
 Ambient relative humidity: 38%  
 Ambient pressure: 953 hPa

Test object	Test voltage $\hat{u}/\sqrt{2}$	Calibration charge	Noise	Result
A	42 kV	10 pC	$\leq 3$ pC	PD-level $\leq 3$ pC
B	42 kV	10 pC	$\leq 3$ pC	PD-level $\leq 3$ pC
C	42 kV	10 pC	$\leq 3$ pC	PD-level $\leq 3$ pC
D	42 kV	10 pC	$\leq 3$ pC	PD-level $\leq 3$ pC

Note: All test objects of the same type of termination and cable cross section were tested simultaneously.

Requirement: Partial discharge level shall not exceed 10 pC.

Result: All test objects passed the test.

### 4.3 Impulse voltage at elevated temperature

The test object were exposed to 10 impulses of positive and negative polarity each. Before each series of 10 impulses, 3 calibration impulses of 50%, 65% and 80% of the test voltage level were applied. The recorded impulses are shown in **Figure 5** to **Figure 8**.

Date: 2016-10-11  
 Ambient temperature: 25°C  
 Ambient relative humidity: 38%  
 Ambient pressure: 953 hPa

Test object	Voltage $\hat{u}$	Front time	Time to half-value	Number of impulses	Result
A	±200 kV	1.020 $\mu$ s	49.308 $\mu$ s	10 of each polarity	No breakdown
B		to 1.030 $\mu$ s	to 49.622 $\mu$ s		No breakdown
C	±200 kV	1.106 $\mu$ s	50.106 $\mu$ s	10 of each polarity	No breakdown
D		to 1.278 $\mu$ s	to 50.290 $\mu$ s		No breakdown

Note: All test objects installed on the same cable cross section were tested simultaneously.

Requirement: Each test object shall withstand 10 positive and 10 negative impulses without breakdown.

Result: All test objects passed the test.

Tyco Electronics Raychem GmbH  
a TE Connectivity Ltd. company


HV Lab Ottobrunn




CSTI-O 4x 1\*50mm<sup>2</sup> kabel warmer impuls 10\* +/-200kV  
Environmental Conditions: 953 hPa 38 % 25 °C

Tested by: BAC


No. 1 LI full Upk: 202.252 kV T1: 1.025 us T2: 49.401 us




No. 2 LI full Upk: 201.935 kV T1: 1.024 us T2: 49.472 us




No. 3 LI full Upk: 201.856 kV T1: 1.027 us T2: 49.377 us




No. 4 LI full Upk: 202.025 kV T1: 1.020 us T2: 49.477 us




No. 5 LI full Upk: 201.948 kV T1: 1.027 us T2: 49.506 us




No. 6 LI full Upk: 201.880 kV T1: 1.030 us T2: 49.543 us




No. 7 LI full Upk: 201.861 kV T1: 1.029 us T2: 49.397 us




No. 8 LI full Upk: 201.533 kV T1: 1.025 us T2: 49.431 us



No. 9 LI full Upk: 201.886 kV T1: 1.026 us T2: 49.548 us



No. 10 LI full Upk: 201.834 kV T1: 1.026 us T2: 49.622 us




1/2

Figure 5: Positive impulses at elevated temperature on test objects A and B (50 mm<sup>2</sup>)


CSTI-O 4x 1\*50mm<sup>2</sup> kabel warmer impuls 10\* +200kV  
Environmental Conditions: 953 hPa 38% 25 °C

Tested by: BAC


No. 1 LI full Upk: -201.222 kV T1: 1.024 us T2: 49.415 us




No. 2 LI full Upk: -201.462 kV T1: 1.022 us T2: 49.319 us




No. 3 LI full Upk: -201.408 kV T1: 1.027 us T2: 49.324 us




No. 4 LI full Upk: -201.443 kV T1: 1.023 us T2: 49.341 us




No. 5 LI full Upk: -201.416 kV T1: 1.022 us T2: 49.346 us




No. 6 LI full Upk: -201.506 kV T1: 1.021 us T2: 49.308 us




No. 7 LI full Upk: -201.479 kV T1: 1.022 us T2: 49.325 us




No. 8 LI full Upk: -201.361 kV T1: 1.020 us T2: 49.402 us



No. 9 LI full Upk: -201.400 kV T1: 1.023 us T2: 49.338 us



No. 10 LI full Upk: -201.296 kV T1: 1.020 us T2: 49.352 us




2 / 2


Figure 6: Negative impulses at elevated temperature on test objects A and B (50 mm<sup>2</sup>)

CSTI/O 150mm<sup>2</sup> 42kV  
Environmental Conditions: 954 hPa 38 % 25 °C Tested by: BAC


No. 1 LI full Upk: 200.354 kV T1: 1.269 us T2: 50.192 us




No. 2 LI full Upk: 200.433 kV T1: 1.223 us T2: 50.120 us




No. 3 LI full Upk: 200.430 kV T1: 1.264 us T2: 50.290 us




No. 4 LI full Upk: 200.550 kV T1: 1.278 us T2: 50.284 us




No. 5 LI full Upk: 200.233 kV T1: 1.267 us T2: 50.241 us




No. 6 LI full Upk: 200.588 kV T1: 1.273 us T2: 50.157 us




No. 7 LI full Upk: 200.526 kV T1: 1.229 us T2: 50.113 us



No. 8 LI full Upk: 200.602 kV T1: 1.278 us T2: 50.276 us



No. 9 LI full Upk: 200.444 kV T1: 1.269 us T2: 50.202 us



No. 10 LI full Upk: 200.332 kV T1: 1.277 us T2: 50.192 us




Figure 7: Positive impulses at elevated temperature on test objects C and D (150 mm<sup>2</sup>)



CST/O 150mm2 42kV

Environmental Conditions:


954 hPa

38 %


25 °C

Tested by: BAC


No. 1 LI full Upk: -199.731 kV T1: 1.210 us T2: 50.251 us




No. 3 LI full Upk: -200.198 kV T1: 1.269 us T2: 50.227 us




No. 4 LI full Upk: -200.324 kV T1: 1.265 us T2: 50.175 us




No. 5 LI full Upk: -200.564 kV T1: 1.271 us T2: 50.106 us




No. 6 LI full Upk: -200.460 kV T1: 1.264 us T2: 50.177 us




No. 7 LI full Upk: -200.493 kV T1: 1.265 us T2: 50.177 us




No. 8 LI full Upk: -200.425 kV T1: 1.264 us T2: 50.190 us




No. 9 LI full Upk: -200.408 kV T1: 1.277 us T2: 50.157 us



No. 10 LI full Upk: -200.408 kV T1: 1.265 us T2: 50.173 us



No. 11 LI full Upk: -200.482 kV T1: 1.274 us T2: 50.136 us



2/2

Figure 8: Negative impulses at elevated temperature on test objects C and D (150 mm<sup>2</sup>)

#### 4.4 Heating cycle voltage in air

The recorded values of the test voltage, heating current, ambient temperature and cable conductor temperature are shown in **Figure 9**.


Date: 2016-10-14 to 2016-12-14

Test object	Test voltage $\hat{u}/\sqrt{2}$	Time of heating	Time of cooling	Number of cycles	Result
A	52 kV	5 h	3 h	126	No breakdown
B					No breakdown
C	52 kV	5 h	3 h	126	No breakdown
D					No breakdown

Note: All test objects installed on the same cable cross section were tested simultaneously.

Requirement: No breakdown shall occur.

Result: All test objects passed the test.



**Figure 9:** Recorded values of ambient temperature (yellow), cable conductor temperature 50mm<sup>2</sup> (orange) and cable conductor temperature 150mm<sup>2</sup> (red) during heat cycle voltage test in air


## 4.5 Immersion test for outdoor terminations

The recorded values ambient temperature and cable conductor temperatures are shown in **Figure 10** and **Figure 11**.


Date: 2017-01-03 to 2017-01-07 (test object B)  
2017-01-10 to 2017-01-14 (test object D)

Test object	Time of heating	Time of cooling	Number of cycles	Result
A	n/a			-
B	5 h	3 h	10	
C	n/a			-
D	5 h	3 h	10	

Result: All test objects passed the test.



**Figure 10:** Recorded values of ambient temperature (green) and cable conductor temperature 50 mm<sup>2</sup> (red) during immersion test of test objects B



**Figure 11:** Recorded values of ambient temperature (green) and cable conductor temperature 150 mm<sup>2</sup> (red) during immersion test of test objects D

## 4.6 Partial discharge at elevated and ambient temperature

### 4.6.1 Elevated temperature

Date: 2016-12-15 (Test object A and C)  
 Ambient temperature: 25°C  
 Ambient relative humidity: 33%  
 Ambient pressure: 960 hPa

Date: 2017-01-09 (Test object B)  
 Ambient temperature: 25°C  
 Ambient relative humidity: 30%  
 Ambient pressure: 960 hPa

Date: 2017-01-16 (Test object D)  
 Ambient temperature: 25°C  
 Ambient relative humidity: 30%  
 Ambient pressure: 960 hPa

Test object	Test voltage $\hat{u}/\sqrt{2}$	Time of heating	Calibration charge	Noise	Result
A	42 kV	5 h	10 pC	$\leq 3$ pC	PD-level $\leq 3$ pC
B					PD-level $\leq 3$ pC
C	42 kV	5 h	10 pC	$\leq 3$ pC	PD-level $\leq 3$ pC
D					PD-level $\leq 3$ pC

Note: All test objects installed on the same cable cross section were tested simultaneously.

Requirement: Partial discharge level shall not exceed 10 pC.

Result: All test objects passed the test.

### 4.6.2 Ambient temperature

Date: 2016-12-15 (Test object A and C)  
 Ambient temperature: 25°C  
 Ambient relative humidity: 33%  
 Ambient pressure: 960 hPa

Date: 2017-01-11 (Test object B)  
 Ambient temperature: 25°C  
 Ambient relative humidity: 30%  
 Ambient pressure: 960 hPa

Date: 2017-01-17 (Test object D)  
Ambient temperature: 25°C  
Ambient relative humidity: 30%  
Ambient pressure: 963 hPa

Test object	Test voltage $\hat{u}/\sqrt{2}$	Calibration charge	Noise	Result
A	42 kV	10 pC	$\leq 3$ pC	PD-level $\leq 3$ pC
B	42 kV	10 pC	$\leq 3$ pC	PD-level $\leq 3$ pC
C	42 kV	10 pC	$\leq 3$ pC	PD-level $\leq 3$ pC
D	42 kV	10 pC	$\leq 3$ pC	PD-level $\leq 3$ pC

Note: All test objects of the same type of termination and cable cross section were tested simultaneously.

Requirement: Partial discharge level shall not exceed 10 pC.

Result: All test objects passed the test.

## 4.7 Impulse voltage at ambient temperature

The test object were exposed to 10 impulses of positive and negative polarity each. Before each series of 10 impulses, 3 calibration impulses of 50%, 65% and 80% of the test voltage level were applied. The recorded impulses are shown in **Figure 12** to **Figure 19**.

Date: 2016-12-16 (Test object A and C)  
 Ambient temperature: 25°C  
 Ambient relative humidity: 33%  
 Ambient pressure: 963 hPa

Date: 2017-01-11 (Test object B)  
 Ambient temperature: 25°C  
 Ambient relative humidity: 30%  
 Ambient pressure: 960 hPa

Date: 2017-01-17 (Test object D)  
 Ambient temperature: 25°C  
 Ambient relative humidity: 30%  
 Ambient pressure: 963 hPa

Test object	Voltage $\hat{u}$	Front time	Time to half-value	Number of impulses	Result
A	$\pm 200$ kV	1.201 $\mu$ s to 1.282 $\mu$ s	50.130 $\mu$ s to 50.428 $\mu$ s	10 of each polarity	No breakdown
B	$\pm 200$ kV	1.064 $\mu$ s to 1.098 $\mu$ s	49.695 $\mu$ s to 49.920 $\mu$ s	10 of each polarity	No breakdown
C	$\pm 200$ kV	1.494 $\mu$ s to 1.532 $\mu$ s	50.682 $\mu$ s to 50.876 $\mu$ s	10 of each polarity	No breakdown
D	$\pm 200$ kV	1.280 $\mu$ s to 1.315 $\mu$ s	50.109 $\mu$ s to 50.373 $\mu$ s	10 of each polarity	No breakdown

Note: All test objects of the same type of termination and cable cross section were tested simultaneously.


Requirement: Each test object shall withstand 10 positive and 10 negative impulses without breakdown.

Result: All test objects passed the test.


CSTI-O 50mm2 Loop 1+2 indoor kalter Impuls 10x+-200kV  
Environmental Conditions: 963 hPa 33% 25 °C

Tested by: BAC


No. 1 LI full Upk: 201.375 kV T1: 1.226 us T2: 50.226 us




No. 2 LI full Upk: 201.391 kV T1: 1.278 us T2: 50.276 us




No. 3 LI full Upk: 201.263 kV T1: 1.262 us T2: 50.428 us




No. 4 LI full Upk: 201.490 kV T1: 1.231 us T2: 50.203 us




No. 5 LI full Upk: 201.640 kV T1: 1.223 us T2: 50.295 us




No. 6 LI full Upk: 201.432 kV T1: 1.270 us T2: 50.231 us




No. 7 LI full Upk: 201.490 kV T1: 1.228 us T2: 50.246 us



No. 8 LI full Upk: 201.380 kV T1: 1.229 us T2: 50.130 us



No. 9 LI full Upk: 201.025 kV T1: 1.217 us T2: 50.404 us



No. 10 LI full Upk: 201.121 kV T1: 1.282 us T2: 50.357 us





Figure 12: Positive impulses at ambient temperature on test object A (50 mm<sup>2</sup>)




CSTI-O 50mm2 Loop 1+2 indoor kalter Impuls 10x+-200kV  
Environmental Conditions: 963 hPa 33% 25 °C

Tested by: BAC


No. 1 LI full Upk: -200.883 kV T1: 1.251 us T2: 50.235 us




No. 2 LI full Upk: -200.804 kV T1: 1.201 us T2: 50.189 us




No. 3 LI full Upk: -200.668 kV T1: 1.209 us T2: 50.225 us




No. 4 LI full Upk: -200.687 kV T1: 1.266 us T2: 50.169 us




No. 5 LI full Upk: -200.550 kV T1: 1.238 us T2: 50.195 us




No. 6 LI full Upk: -200.971 kV T1: 1.209 us T2: 50.138 us




No. 7 LI full Upk: -200.496 kV T1: 1.244 us T2: 50.240 us



No. 8 LI full Upk: -200.670 kV T1: 1.244 us T2: 50.199 us



No. 9 LI full Upk: -200.594 kV T1: 1.250 us T2: 50.239 us



No. 10 LI full Upk: -200.834 kV T1: 1.202 us T2: 50.130 u





Figure 13: Negative impulses at ambient temperature on test object A (50 mm<sup>2</sup>)



CSTI-O 50mm2 Loop 3+4 outdoor kalter Impuls  $\square$  10x +200kV


Environmental Conditions: 25 hPa 30% 950 °C Tested by: BAC

LI full Upk: 199.247 kV T1: 1.097 us T2: 49.804 us




10/27/2016 12:26:48

LI full Upk: 200.670 kV T1: 1.086 us T2: 49.860 us




10/27/2016 12:27:09

LI full Upk: 201.025 kV T1: 1.081 us T2: 49.791 us




10/27/2016 12:27:30

LI full Upk: 200.684 kV T1: 1.093 us T2: 49.794 us




10/27/2016 12:27:51

LI full Upk: 200.785 kV T1: 1.083 us T2: 49.820 us




10/27/2016 12:28:12

LI full Upk: 200.894 kV T1: 1.092 us T2: 49.858 us




10/27/2016 12:28:33

LI full Upk: 201.058 kV T1: 1.093 us T2: 49.840 us




10/27/2016 12:28:54

LI full Upk: 200.580 kV T1: 1.098 us T2: 49.920 us




10/27/2016 12:29:15

LI full Upk: 200.646 kV T1: 1.094 us T2: 49.877 us



10/27/2016 12:29:35

LI full Upk: 200.646 kV T1: 1.094 us T2: 49.865 us



10/27/2016 12:29:56

1 / 2


Figure 14: Positive impulses at ambient temperature on test object B (50 mm<sup>2</sup>)




CSTI-O 50mm2 Loop 3+4 outdoor kalter Impuls  $\square$  10x +200kV

Environmental Conditions: 25 hPa 30 % 950 °C Tested by: BAC


LI full Upk: -201.476 kV T1: 1.069 us T2: 49.734 us




LI full Upk: -201.744 kV T1: 1.065 us T2: 49.711 us




LI full Upk: -201.566 kV T1: 1.069 us T2: 49.695 us




LI full Upk: -201.550 kV T1: 1.067 us T2: 49.737 us




LI full Upk: -201.591 kV T1: 1.070 us T2: 49.730 us




LI full Upk: -201.498 kV T1: 1.073 us T2: 49.727 us




LI full Upk: -201.350 kV T1: 1.070 us T2: 49.765 us



LI full Upk: -201.430 kV T1: 1.064 us T2: 49.800 us



LI full Upk: -201.427 kV T1: 1.070 us T2: 49.797 us



LI full Upk: -201.307 kV T1: 1.067 us T2: 49.756 us




Figure 15: Negative impulses at ambient temperature on test object B (50 mm<sup>2</sup>)

Tyco Electronics Raychem GmbH  
a TE Connectivity Ltd. company


HV Lab Ottobrunn




CSTI-O 150mm<sup>2</sup> Loop 1+2 indoor kalter Impuls 10x+- 200kV  
Environmental Conditions: 963 hPa 33 % 25 °C

Tested by: BAC


No. 1 LI full Upk: 200.602 kV T1: 1.532 us T2: 50.772 us




No. 2 LI full Upk: 200.373 kV T1: 1.523 us T2: 50.781 us




No. 3 LI full Upk: 200.498 kV T1: 1.530 us T2: 50.812 us




No. 4 LI full Upk: 200.395 kV T1: 1.530 us T2: 50.820 us




No. 5 LI full Upk: 200.427 kV T1: 1.515 us T2: 50.799 us




No. 6 LI full Upk: 200.580 kV T1: 1.522 us T2: 50.801 us




No. 7 LI full Upk: 200.430 kV T1: 1.518 us T2: 50.757 us




No. 8 LI full Upk: 200.509 kV T1: 1.516 us T2: 50.759 us



No. 9 LI full Upk: 200.233 kV T1: 1.522 us T2: 50.876 us



No. 10 LI full Upk: 200.430 kV T1: 1.517 us T2: 50.758 us




1/2

Figure 16: Positive impulses at ambient temperature on test object C (150 mm<sup>2</sup>)


CSTI-O 150mm<sup>2</sup> Loop 1+2 indoor kalter Impuls 10x+- 200kV  
Environmental Conditions: 963 hPa 33 % 25 °C

Tested by: BAC


No. 1 LI full Upk: -200.476 kV T1: 1.500 us T2: 50.732 us




No. 2 LI full Upk: -200.430 kV T1: 1.514 us T2: 50.754 us




No. 3 LI full Upk: -200.452 kV T1: 1.507 us T2: 50.719 us




No. 4 LI full Upk: -200.310 kV T1: 1.513 us T2: 50.757 us




No. 5 LI full Upk: -200.228 kV T1: 1.515 us T2: 50.834 us




No. 6 LI full Upk: -200.818 kV T1: 1.512 us T2: 50.751 us




No. 7 LI full Upk: -200.572 kV T1: 1.513 us T2: 50.709 us



No. 8 LI full Upk: -200.646 kV T1: 1.499 us T2: 50.769 us



No. 9 LI full Upk: -200.386 kV T1: 1.495 us T2: 50.682 us



No. 10 LI full Upk: -200.395 kV T1: 1.500 us T2: 50.789 us





Figure 17: Negative impulses at ambient temperature on test object C (150 mm<sup>2</sup>)


CSTI-O 150mm<sup>2</sup> Loop 3+4 outdoor kalter Impuls  $\square$  10x  $\pm$ 200kV

Environmental Conditions: 960 hPa 30% 25 °C Tested by: BAC


LI full Upk: 200.807 kV T1: 1.315 us T2: 50.287 us




LI full Upk: 200.900 kV T1: 1.296 us T2: 50.373 us




LI full Upk: 201.132 kV T1: 1.311 us T2: 50.219 us




LI full Upk: 201.320 kV T1: 1.308 us T2: 50.249 us




LI full Upk: 201.047 kV T1: 1.300 us T2: 50.330 us




LI full Upk: 200.676 kV T1: 1.314 us T2: 50.286 us




LI full Upk: 201.167 kV T1: 1.294 us T2: 50.355 us



LI full Upk: 201.066 kV T1: 1.296 us T2: 50.282 us



LI full Upk: 201.408 kV T1: 1.302 us T2: 50.275 us



LI full Upk: 201.345 kV T1: 1.311 us T2: 50.221 us





Figure 18: Positive impulses at ambient temperature on test object D (150 mm<sup>2</sup>)

**CSTI-O 150mm<sup>2</sup> Loop 3+4 outdoor kalter Impuls □□10x +-200kV**

Environmental Conditions: 960 hPa 30 % 25 °C Tested by: BAC



**Figure 19:** Negative impulses at ambient temperature on test object D (150 mm<sup>2</sup>)

## 4.8 AC voltage dry withstand

Date: 2016-12-16 (Test object A and C)  
 Ambient temperature: 25°C  
 Ambient relative humidity: 33%  
 Ambient pressure: 963 hPa

Date: 2017-01-11 (Test object B)  
 Ambient temperature: 25°C  
 Ambient relative humidity: 30%  
 Ambient pressure: 960 hPa

Date: 2017-01-17 (Test object D)  
 Ambient temperature: 25°C  
 Ambient relative humidity: 30%  
 Ambient pressure: 963 hPa

Test object	Test voltage $\hat{u}/\sqrt{2}$	Duration	Result
A	93,5 kV	5 min	No breakdown
B			No breakdown
C	93,5 kV	5 min	No breakdown
D			No breakdown

Note: All test objects installed on the same cable cross section were tested simultaneously.

Requirement: No breakdown shall occur.

Result: All test objects passed the test.



## 4.9 Partial discharge at ambient temperature

Date: 2016-12-16 (Test object A and C)  
 Ambient temperature: 25°C  
 Ambient relative humidity: 33%  
 Ambient pressure: 963 hPa

Date: 2017-01-11 (Test object B)  
 Ambient temperature: 25°C  
 Ambient relative humidity: 30%  
 Ambient pressure: 960 hPa

Date: 2017-01-17 (Test object D)  
 Ambient temperature: 25°C  
 Ambient relative humidity: 30%  
 Ambient pressure: 963 hPa

Test object	Test voltage $\hat{u}/\sqrt{2}$	Calibration charge	Noise	Result
A	42 kV	10 pC	$\leq 3$ pC	PD-level $\leq 3$ pC
B	42 kV	10 pC	$\leq 3$ pC	PD-level $\leq 3$ pC
C	42 kV	10 pC	$\leq 3$ pC	PD-level $\leq 3$ pC
D	42 kV	10 pC	$\leq 3$ pC	PD-level $\leq 3$ pC

Note: All test objects of the same type of termination and cable cross section were tested simultaneously.

Requirement: Partial discharge level shall not exceed 10 pC.

Result: All test objects passed the test.

## 4.10 Examination

Date: 2016-12-08 (CSTI-6122-ML-2-13)  
 2017-01-27 (CSTO-6122-ML-2-13)

The test samples were examined for the following criteria:

- (i) cracking in the filling media and/or tape or tube components
- (ii) a moisture path bridging a primary seal
- (iii) corrosion and/or tracking and/or erosion

(iv) leakage of any insulating material

Test object	Criteria (i)	Criteria (ii)	Criteria (iii)	Criteria (iv)
A	Not found	Not found	Not found	Not found
B	Not found	Not found	Not found	Not found

#### 4.11 Humidity test

The four test objects before and after the humidity test are shown in **Figure 20** to **Figure 27**.

Date: 2016-12-20 – 2017-01-02 (Test object E)

Test object	Test voltage $\hat{u}/\sqrt{2}$	Duration	Result
A	26 kV	300 h	No breakdown nor flashover, no more than 3 strips, no substantial damage

Requirement: No breakdown nor flashover, no more than 3 strips, no substantial damage

Result: All test objects passed the test.



**Figure 20:** Sample 1A  
before 300 h



**Figure 21:** Sample 1B  
before 300 h



**Figure 22:** Sample 2A  
before 300 h



**Figure 23:** Sample 2B  
before 300 h



**Figure 24:** Sample 1A  
after 300 h



**Figure 25:** Sample 1B  
after 300 h



**Figure 26:** Sample 2A  
after 300 h



**Figure 27:** Sample 2B  
after 300 h

## 4.12 Examination

Date: 2017-01-02 (CSTI-6122-ML-2-13)

The test samples were examined for the following criteria:

(v) cracking in the filling media and/or tape or tube components

(vi) a moisture path bridging a primary seal

(vii) corrosion and/or tracking and/or erosion

(viii) leakage of any insulating material

<b>Test object</b>	<b>Criteria (i)</b>	<b>Criteria (ii)</b>	<b>Criteria (iii)</b>	<b>Criteria (iv)</b>
E	Not found	Not found	Not found	Not found

## A. Appendices

### A.1 Identification of test cable 50mm<sup>2</sup>

Rated voltage  $U_0/U (U_m)$ : 18/30 (36) kV

Cable construction:  1-core  3-core  Individually screen  
 Overall screen

Conductors:  Al  Cu  
 Stranded  Solid  
 Circular  Shaped  
 120mm<sup>2</sup>  150mm<sup>2</sup>  185mm<sup>2</sup>  
 240mm<sup>2</sup>  
 Other cross section: 50 mm<sup>2</sup>

Insulation:  XLPE  Other:  
 EPR  HEPR

Insulation screen:  Bonded  Strippable

Metallic screen:  Wires  Tapes  Extruded  
 Al  Cu  Other

Armour:  Wire  Tape

Oversheath:  PVC  PE (state type)

Water blocking, if any:  Within conductor  Under oversheath

Diameters: Conductor: 8.5 mm  
 Insulation: 25.2 mm  
 Insulation screen: 26.5 mm  
 Oversheath: 33.0 mm

Cable marking: VDE0276 FACAB 50301 N2XSY 1 x 50RM/16mm<sup>2</sup> 18/30 (36)kV  
 2016

## A.2 Identification of test cable 150mm<sup>2</sup>

Rated voltage  $U_0/U (U_m)$ : 18/30 (36) kV

Cable construction:  1-core  3-core  Individually screen

Overall screen

Conductors:  Al  Cu

Stranded  Solid

Circular  Shaped

120mm<sup>2</sup>  150mm<sup>2</sup>  185mm<sup>2</sup>

240mm<sup>2</sup>

Other cross section: - mm<sup>2</sup>

Insulation:  XLPE  Other:

EPR  HEPR

Insulation screen:  Bonded  Strippable

Metallic screen:  Wires  Tapes  Extruded

Al  Cu  Other

Armour:  Wire  Tape

Oversheath:  PVC  PE (state type)

Water blocking, if any:  Within conductor  Under oversheath

Diameters: Conductor: 13.7 mm

Insulation: 30.5 mm

Insulation screen: 32.2 mm

Oversheath: 40.0 mm

Cable marking: FACAB 60102 NA2XS2Y 1 x 150RM/25 30kV 2010

### A.3 Identification of test cable 95mm<sup>2</sup>

Rated voltage  $U_0/U (U_m)$ : 18/30 (36) kV

Cable construction:  1-core  3-core  Individually screen  
 Overall screen

Conductors:  Al  Cu  
 Stranded  Solid  
 Circular  Shaped  
 120mm<sup>2</sup>  150mm<sup>2</sup>  185mm<sup>2</sup>  
 240mm<sup>2</sup>  
 Other cross section: 95 mm<sup>2</sup>

Insulation:  XLPE  Other:  
 EPR  HEPR

Insulation screen:  Bonded  Strippable

Metallic screen:  Wires  Tapes  Extruded  
 Al  Cu  Other

Armour:  Wire  Tape

Oversheath:  PVC  PE (state type)

Water blocking, if any:  Within conductor  Under oversheath


Diameters: Conductor: 11.5 mm  
 Insulation: 28.5 mm  
 Insulation screen: 29.9 mm  
 Oversheath: 37.0 mm

Cable marking: VDE 0276 NA2XS(F)2Y 1 x 95/16 RM 18/30kV 2015 FACAB 06201

## A.4 Installation instructions



**Raychem**  
from TE Connectivity



**Installation Instruction**  
**EPP-2828-8/16**

**Raychem**  
**Termination for Screened**  
**Single Core Polymeric Cable**  
**without Armour**

**Type: CSTI/CSTO**  
**Indoor/Outdoor**

**36 kV / 42 kV**

To view the TE Energy website:



**Tyco Electronics Raychem GmbH**  
a TE Connectivity Ltd. Company  
TE Energy  
Finsinger Feld 1  
85521 Ottobrunn/Munich, Germany  
Tel: +49-89-6089-0  
Fax: +49-89-6096-345  
energy.te.com





## **Before Starting**

Check to ensure that the kit you are going to use is suitable for the size of cables being joined.

Refer to the kit label and the title of the installation instruction.

Components or working steps may have been modified since you last installed this product.

Carefully read and follow the steps in the installation instruction.

## **General Instructions**

Clean and degrease all parts that will come into contact with adhesive.

If a solvent is used follow the manufacturer's handling instructions.

Check cable ends for ingress of moisture before starting with cable preparation.

For easy strip screen layers always use a round file to cut radially through the core screen.

The Information contained in these installation instructions is for use only by installers trained to make electrical power installations and is intended to describe the correct method of installation for this product. However, TE Connectivity has no control over the field conditions which influence product installation.

It is the user's responsibility to determine the suitability of the installation method in the user's field conditions. TE Connectivity's only obligations are those in TE Connectivity's standard Conditions of Sale for this product and in no case will TE Connectivity be liable for any other incidental, indirect or consequential damages arising from the use or misuse of the products.

Raychem, TE, TE Connectivity and TE connectivity (logo) are trademarks.

© 2016 TE Connectivity. All Rights Reserved.

## Cable Preparation

### Before Starting

Check to ensure that the kit you are going to use fits the cable.  
 Refer to the kit label and the title of the installation instruction.  
 Components or work steps may have been improved since you last installed this product.  
 Carefully read and follow the steps in the installation instruction.


Table for cutback dimensions

Mechanical lug BLMT	Cable	Termination
	Cross Section mm <sup>2</sup>	Indoor/Outdoor 36 kV/42 kV mm
BLMT 25/95	95	435
BLMT 35/150	50 Cu	460
BLMT 35/150	150 Al	450
BLMT 95/240	185	475
BLMT 95/240	240	440
BLMT 120/300	120 – 300	
BLMT 185/400	185	475
	400	445
BLMT 500/630	500 Al	485
BLMT 500/630	630 Al	485
BLMT 500/630	630 Cu	485
BLMT 800/1000	1000 Al	460

#### For cable cross section 50 - 630 mm<sup>2</sup>

Cut the cable to the required length.  
 Remove the oversheath according to L. Clean and degrease the end of the oversheath for approximately 100 mm.


Mark a line 70 mm below the oversheath cut.




#### For cable cross section 800 - 100 mm<sup>2</sup>


Cut the cable to the required length.  
 Remove the oversheath according to L. Clean and degrease the end of the oversheath for approximately 100 mm.

Mark a line 60 mm below the oversheath cut.




Wrap two layers of sealant tape (grey) with a small overlap and slight tension around the end of the oversheath as shown. Bend the shielding wires back onto the oversheath. Avoid crossing the individual wires. Fix the shielding wires with a tape to the oversheath.






3  
Thoroughly remove the core screen to within 40 mm of the overshoot cut. The surface of the insulation should be free from all traces of conductive material. Smooth out any irregularities.

**Note:** Do not nick the insulation.



4  
Cut back the insulation according to **Mechanical lugs:**  
**K = depth of cable lug barrel hole**  
Install the cable lug and remove all sharp edges. Clean and degrease the core insulation and the lug.



5  
Apply a thin layer of silicone grease onto the insulation and the core screen cut.  
Position the termination body.  
Pull the spiral gently until the termination body butts to the reference line.  
If the termination is not correctly positioned, it is possible to gently slide it into place.



Remove the spiral holdout completely from the termination by pulling it counterclockwise.

Do not twist the spiral holdout during removal. Avoid the spiral to hook up over the termination.

Degrease and clean the termination.

Fix the shield wires with a wire binder along the lower edge of the termination body. Install the cable lug on the shield wires.

**Termination completed.**





Please dispose of all waste according to local environmental regulations.



### CSTI/CSTO – Product family

Indoor

Outdoor



Min. clearances	Max. system voltage in kV	
	36	42
<b>a</b> Air clearance	as for local specifications	
<b>b</b> ph/ph and ph/ground in mm	35	45
<b>d</b> Between skirts in mm	25	35

## A.5 Kit content lists

### CSTI-6122-ML-2-13

482406-000	S1278-1-300(B100)
EK3103-001	EPP-2828-8/16
E74727-000	EPPA-004
724277N001	EXRM-0568
CV2903-000	EPPA-076-5
989771-000	EPPA-029-3-3000
E43601-000	HEL-2070.1-Z-AK
2304321-4	CSTI-35-BD-18-533-FS
F61108-000	BLMT-35/150-13

### CSTO-6122-ML-2-13

482406-000	S1278-1-300(B100)
EK3103-001	EPP-2828-8/16
E74727-000	EPPA-004
724277N001	EXRM-0568
CV2903-000	EPPA-076-5
989771-000	EPPA-029-3-3000
E43601-000	HEL-2070.1-Z-AK
2304322-4	CSTO-35-BD-18-533-FS
F61108-000	BLMT-35/150-13