Laboratory Reference No: 100551



CONTENTS

Test Record

: Pages 1 to 10

Diagram

: Figure 1

Oscillograms No.

: 7380.004,006,007,009,010 and 011

Drawings No.

SC01 SCHD Issue A

29.4.96 Issue A 29.4.96

Photographs No.

: 22507 1A, B, C, D, E, I, K, L, M, N, P, Q and R

APPARATUS TESTED

The apparatus tested consisted of non-tension fittings made up of the following components:

Tests No. 7380.

Type SC01 clamp fitted with a 19/15/0.4 mm bare copper tail cable and

004, 006 and 007

clamped to a 19/2.0 mm bare copper line cable

Tests No. 7380.

Type SCHD clamp fitted with 2 x 19/15/0.4 mm bare copper tail cables

009, 010 and 011 and clamped to a 19/2.0 mm bare copper line cable

CLIENT

Bervic Engineering Co. Pty. Ltd 258 Boundary Road Braeside Victoria 3195 Australia

DATE OF RECEIPT OF TEST ITEMS

28 August 1997

ORDER NUMBER

4440 dated 18 August 1997

NATA Signatory

Laboratory Reference No: 100551



MANUFACTURER

The manufacturer has declared that the apparatus was assembled at the following location:

Bervic Engineering Co. Pty. Ltd 258 Boundary Road Braeside Victoria 3195 Australia

LABORATORY

The apparatus was tested at:



Testing & Certification Australia
Lane Cove Testing Station
18 Mars Road
Lane Cove NSW 2066 Australia
Telephone 61 (0)2 9410 5202, Facsimile 61 (0)2 9428 2645

The laboratory accreditation details are:



This laboratory is registered by the National Association of Testing Authorities, Australia, Registration No. 62. The tests reported herein have been performed in accordance with its terms of registration.



Quality System Certified by NATA to AS/NZS ISO 9002 Registration No. 6702.



ASTA Accredited Laboratory to BS 7501 / EN 45001 / ASTA Publication 31 Registration No. 5118.

M. A. Carstalt NATA Signatory

Page 2 of 10

Laboratory Reference No: 100551



TEST CONDITIONS

- 1. The tests were conducted in generally in accordance with Clause 5.4.3 of Australian Standard 1154.1: 1985, except that the Client specified test currents higher than required by Appendix A of Australian Standard 1154.1: 1985.
- 2. The non-tension fittings were tested with two phases of a three-phase, 50 Hz supply in the circuit shown in Figure 1.
- 3. The test supply was adjusted to the nominal current specified by the Client. The test supply was maintained for the duration specified in the Standard.
- For each test the clamp under test was attached to the line cable and tightened using an operating stick with two hands. The tail cable clamping devices were tightened with spanners.

NATA Signatory

Laboratory Reference No: 100551



Short-time Current Test at 6.93 kA rms for 2 s

Condition Before Test

Clamp

: Type SC01, Sample No. 1 in new condition,

Tail cable

: 2.2 m of 19/15/0.4 mm bare copper cable in new condition.

Line cable

: 19/2.0 mm bare copper cable in new condition.

See Photographs No. 22507 / A and B

Test Circuit Diagram

	Hotograpi	IS NO. 22507 7 A	and b				gure i		
Test	Applied	Current							
No.	Voltage	Asymmetrical		measured	l on	Duration	Average Symmetrical kA rms		
7380.	V	kA peak	0.14 s 1.10 s 2.06 s		s				
004	440	10.72	7.221	7.096	6.941	2.02	7.086		

Observations During Test

Movement of cables. Tail cable glowed red hot.

Condition After Test

No damage to clamp and line cable. Clamp complied with the requirements of Clause 5.4.3.4

Tail cable discoloured and annealed. No signs of local heating, burning or fusing of any part of the clamp or cables where they attach to the clamp.

See Photographs No. 22507 / C, D and E

Date of Test:

3 September 1997

Note: Current initiated at 0.1 s

NATA Signatory

Page 4 of 10

Laboratory Reference No: 100551



Short-time Current Test at 6.93 kA rms for 2 s

Condition Before Test

Clamp

: Type SC01, Sample No. 2 in new condition,

Tail cable

: 1.1 m of 19/15/0.4 mm bare copper cable in new condition.

Line cable

: 19/2.0 mm bare copper cable as after Test No. 7380.004

Test Circuit Diagram

Figure 1

Test	Applied	Current							
No.	Voltage	Asymmetrical	Symmetrical kA rms measured on oscillogram at			Duration	Average Symmetrical kA rms		
7380.	V	kA peak	0.16 s	1.10 s	2.04 s	S			
006	428	10.50	7.108	7.072	6.986	2.01	7.055		

Observations During Test

Movement of cables. Tail cable glowed red hot.

Condition After Test

No damage to clamp and line cable. Clamp complied with the requirements of Clause 5.4.3.4

Tail cable discoloured and annealed. No signs of local heating, burning or fusing of any part of the clamp or cables where they attach to the clamp.

See Photographs No. 22507 / I

Date of Test:

3 September 1997

Note: Current initiated at 0.1 s

NATA Signatory

Page 5 of 10

Laboratory Reference No: 100551



Short-time Current Test at 6.93 kA rms for 2 s

Condition Before Test

Clamp

: Type SC01, Sample No. 3 in new condition,

Tail cable

: 1.1 m of 19/15/0.4 mm bare copper cable in new condition.

Line cable

: 19/2.0 mm bare copper cable as after Test No. 7380.006

Test Circuit Diagram

Figure 1

Test	Applied	Current								
No.	Voltage	Asymmetrical	Symmetrical kA rms measured on oscillogram at			Duration	Average Symmetrical kA rms			
7380.	V	kA peak	0.16 s	1.10 s	2.04 s	s				
007	429	10.47	7.104	7.085	7.012	2.01	7.067			

Observations During Test

Movement of cables. Tail cable glowed red hot.

Condition After Test

No damage to clamp and line cable. Clamp complied with the requirements of Clause 5.4.3.4

Tail cable discoloured and annealed. No signs of local heating, burning or fusing of any part of the clamp or cables where they attach to the clamp.

See Photographs No. 22507 / K

Date of Test:

3 September 1997

Note: Current initiated at 0.1 s

NATA Signatory

Page 6 of 10

Laboratory Reference No: 100551



Short-time Current Test at 13.85 kA rms for 2 s

Condition Before Test

Clamp

: Type SCHD, Sample No. 4 in new condition,

Tail cable

: 0.9 m of 2 x 19/15/0.4 mm bare copper cables in new condition.

Line cable

: 19/2.0 mm bare copper cable as after Test No. 7380.007

See P	hotograph	No. 22507 L					est Circuit Diagram igure 1
Test	Applied	Current					
No.	Voltage	Asymmetrical	Symme kA rms oscillog	measured	on	Duration	Average Symmetrical kA rms
7380.	V	kA peak	0.2 s	1.14 s	2.10 s	s	
009	421	20.75	14.11	14.04	13.87	2.02	14.01

Observations During Test

Movement of cables. Line and tail cables glowed red hot.

Condition After Test

No damage to clamp. Clamp complied with the requirements of Clause 5.4.3.4

Line and tail cables discoloured and annealed. No signs of local heating, burning or fusing of any part of the clamp or cables where they attach to the clamp.

See Photographs No. 22507 / M and N

Date of Test:

6 September 1997

Note: Current initiated at 0.14 s

M.A. Carstell NATA Signatory

Laboratory Reference No: 100551



Short-time Current Test at 13.85 kA rms for 2 s

Condition Before Test

Clamp

: Type SCHD, Sample No. 5 in new condition,

Tail cable

: 0.9 m of 2 x 19/15/0.4 mm bare copper cables in new condition.

Line cable

: 19/2.0 mm bare copper cable in new condition

Test Circuit Diagram
Figure 1

Test	Applied	Current							
No.	Voltage	Asymmetrical	Symmetrical kA rms measured on oscillogram at			Duration	Average Symmetrical kA rms		
7380.	V	kA peak	0.18 s	1.14 s	2.10 s	s			
010	422	20.73	14.19	14.11	13.89	2.02	14.06		

Observations During Test

Movement of cables. Line and tail cables glowed red hot.

Condition After Test

No damage to clamp. Clamp complied with the requirements of Clause 5.4.3.4

Line and tail cables discoloured and annealed. No signs of local heating, burning or fusing of any part of the clamp or cables where they attach to the clamp.

See Photographs No. 22507 / P

Date of Test:

6 September 1997

Note: Current initiated at 0.14 s

M.A. Contest

NATA Signatory

Laboratory Reference No: 100551



Short-time Current Test at 13.85 kA rms for 2 s

Condition Before Test

Clamp

: Type SCHD, Sample No. 6 in new condition,

Tail cable

: 0.9 m of 2 x 19/15/0.4 mm bare copper cables in new condition.

Line cable : 19/2.0 mm bare copper cable in new condition

Test Circuit Diagram

Figure 1

Test	Applied	Current							
No.	Voltage	Asymmetrical	Symmetrical kA rms measured on oscillogram at			Duration	Average Symmetrical kA rms		
7380.	V	kA peak	0.2 s	1.14 s	2.10 s	s			
011	420	20.85	14.15	14.06	13.91	2.02	14.04		

Observations During Test

Movement of cables. Line and clamp cables glowed red hot.

Condition After Test

No damage to clamp. Clamp complied with the requirements of Clause 5.4.3.4

Line and tail cables discoloured and annealed. No signs of local heating, burning or fusing of any part of the clamp or cables where they attach to the clamp.

See Photographs No. 22507 / Q and R

Date of Test:

6 September 1997

Note: Current initiated at 0.14 s

Page 9 of 10

Laboratory Reference No: 100551



PHOTOGRAPHS

Number		Caption
22507	Α	Test arrangement before Test No. 7380.004
	В	SC01 clamp, sample 1 before Test No. 7380.004
	С	Test arrangement after Test No. 7380.004
	D	SC01 clamp, sample 1 after Test No. 7380.004
	E	SC01 clamp, sample 1 after Test No. 7380.004
	1	SC01 clamp, sample 2 after Test No. 7380.006
	K	SC01 clamp, sample 3 after Test No. 7380.007
	L	SCHD clamp, sample 4 before Test No. 7380.009
	М	Test arrangement after Test No. 7380.009
	N	SCHD clamp, sample 4 after Test No. 7380.009
	Р	SCHD clamp, sample 5 after Test No. 7380.010
	Q	Test arrangement after Test No. 7380.011
	R	SCHD clamp, sample 6 after Test No. 7380.011

M.A. Cantedt NATA Signatory

Page 10 of 10